

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2200-0049:003 Page 1 of 1

CATEGORY: Ceiling Systems/Panels

LISTEE: Chicago Metallic, 4849 S. Austin Ave., Chicago, IL 60638
Contact: Tony Ingratta (708) 563-4600

DESIGN: Types 1250, 1260, 1850 and 1860 ceiling suspension system. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING Listee's model or catalog number and UL label.

APPROVAL: Listed for use in fire-resistive ceiling/floor or ceiling/roof assemblies using fire-resistive ceiling panels approved for installation with this grid system. The assembly and beam ratings in designs employing the aluminum capped grid are limited to 2 hours fire resistance.

NOTE: Formerly 1250-0049:003

07-12-93



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 29, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager